Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated : 12.05.2026

It is certified that an inspection team headed by Er. Chetan Chauhan (A.E.) (Name of Officer with Designation) From Uttarakhand Jal Sansthan (Name of Department/ Office) inspected the Nosegay Public School, Khatima, U.S.Nagar (Name & Address of the School) on 12.05.2026 (Date of Inspection) and on the basis of Water test Report (Attached) bearing No. 05/UJS/DLWQTML/2026-27 dated 07-05-2026 of DLWQTML/UJS (PHED Lab) certified that the Nosegay Public School (Name of the School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 Year.

अधिशासी आभियन्ता
उत्तराखण्ड जल संस्थान
ऊधम सिंह नगर

Signature with Seal :
Name : Er. Chetan Chauhan
Designation : A.E.
Name & Address of the office / Department:
Uttarakhand Jal Sansthan, Rudrapur.

To,

_____

_____

_____

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

District Level Water Quality Testing and Monitoring LaboratoryUttarakhand Jal Sansthan, Collectrate Campus,Rudrapur(U.S.Nagar)

TEST REPORT

Name and Address of Organization/ Customer	Nosegay Public School, Khatima U.S.Nagar Uttarakhand		
Reference Sample Identification	05/UJS/DLWQTML/2026-27	**Reporting Date**	07/05/2026
ULR No.	-	**Sample Location**	Sample-01,UV Filter
Product Description	Drinking Water	**Sample Submitted by**	Customer
Reference Sample Identification:	DLWQTML/UJS/2026/05		
Duration of Analysis:	06/05/2026 to 07/05/2026		
Date and Time of Sample Received:	06/05/2026 & 02:15PM		

SN	Parameters	Test Method	Result	Acceptable Limit As per (IS10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1.	**pH at 25^{0}C**	IS 3025 (Part 11) 2022,	7.69	6.5 to 8.5	No Relaxation
2.	**Total Dissolved Solids (TDS), at 180^{0}C mg/L**	IS 3025 (Part 16), 2023	300	500Max	2000Max
3.	**Turbidity, NTU**	IS 3025 (Part 10), 2023	0.73	1Max	5Max
4.	**Total Alkalinity (as $CaCO_3$), mg/L**	IS 3025 (Part 23), 2023	182	200Max	600Max
5.	**Total Hardness (as $CaCO_3$), mg/L**	IS 3025 (Part 21), 2009	162	200Max	600Max
6.	**Calcium as Ca, mg/l**	IS 3025 (Part 40), 2019	49.60	75Max	200Max
7.	**Chloride, mg/L**	IS 3025 (Part 32),2019	12.98	250Max	1000Max
8.	**Magnesium as Mg, mg/l**	APHA 24th Ed -3500-Mg Method B:2023 (Calculation Method)	14.09	30Max	100Max
9.	**Colour, Hazen, *Max***	IS 3025 (Part 4): 2021	Less than 5	5Max	15Max
10.	**Odour**	IS 3025 (Part 5) : 2018	Agreeable	Agreeable	Agreeable

Note:
1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after 15 days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5.The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

Review and Authorized by

Technical Manager
District Water Quality Testing
Monitoring Laboratory
Uttarakhand Jal Sansthan, U.S.Nagar

(Er. MUKESH KUMAR)
Technical Manager,Lab

District Level Water Quality Testing and Monitoring LaboratoryUttarakhand Jal Sansthan, Collectrate Campus,Rudrapur(U.S.Nagar)

Name and Address of Organization/ Customer	Nosegay Public School, Khatima U.S.Nagar Uttarakhand		
Test Report ID	05A/UJS/DLWQTML/2026-27	**Reporting Date**	07/05/2026
Product Description	Drinking Water	**Sample Location**	Sample-01,UV Filter
Reference Sample Identification:	DLWQTML/UJS/2026/05	**Sample Collected by**	Customer
Date of Start of Analysis:	06/05/2026		
Date of End of Analysis:	07/05/2026		
Date and Time of Sample Received:	06/05/2026 & 02:15PM		

SN	Parameters	Test Method	Results	Acceptable Limit As per (IS 0500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1	Total Coliform, MPN/ 100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent
2	E. coli, MPN/ 100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after 15 days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

Review and Authorized by

(Er. MUKESH KUMAR)
Technical Manager

Technical Manager
District Water Quality Testing
Monitoring Laboratory
Uttarakhand Jal Sansthan, U.S.Nagar